

Flame Certificate

Wend
466381

maharam

Wend was tested and met the following flammability requirements:

Seating: California Bulletin #117-2013

Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 80

Contact clientservices@maharam.com with any questions.