

Flame Certificate
Leaflet Plaid
502408

maharam

Leaflet Plaid was tested and met the following flammability requirements:

Privacy Curtain: NFPA 701 - 1999 Test Method #1

Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 35

Windows: NFPA 701 - 1999 Test Method #1

Contact clientservices@maharam.com with any questions.