

## Flame Certificate

Laurel

511473

**maharam**

Laurel was tested and met the following flammability requirements:

Privacy Curtain: NFPA 701

Upholstered Walls: ASTM E 84 Unadhered

Windows: NFPA 701

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.