

Flame Certificate  
Progression 2  
511477

**maharam**

Progression 2 was tested and met the following flammability requirements:

Privacy Curtain: NFPA 701

Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 50

Windows: NFPA 701

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.