

Flame Certificate  
Tabby Check  
511487

**maharam**

Tabby Check was tested and met the following flammability requirements:

Privacy Curtain: NFPA 701

Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 60

Windows: NFPA 701

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.