

Flame Certificate  
Bloom  
511497

**maharam**

Bloom was tested and met the following flammability requirements:

Privacy Curtain: NFPA 701

Upholstered Walls: ASTM E 84 Unadhered flame 10, smoke 105

Windows: NFPA 701

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.