

Flame Certificate
Sharkskin 2
901650

maharam

Sharkskin 2 was tested and met the following flammability requirements:
Upholstered Walls: ASTM E 84 Unadhered flame 15, smoke 55

Contact clientservices@maharam.com with any questions.