

Flame Certificate

Morse

901720

maharam

Morse was tested and met the following flammability requirements:

Systems: ASTM E 84 Unadhered flame 5, smoke 105

Upholstered Walls: ASTM E 84 Unadhered

Contact clientservices@maharam.com with any questions.