

Flame Certificate
Tek-Wall Lucent
300066

maharam

Tek-Wall Lucent was tested and met the following flammability requirements:
Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 115
Walls: ASTM E 84 Adhered flame 10, smoke 25

Contact clientservices@maharam.com with any questions.