

Flame Certificate
Vinex Atlas / P091
399582

maharam

Vinex Atlas / P091 was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact clientservices@maharam.com with any questions.