

Flame Certificate  
Mixed Stripe  
by Paul Smith  
399652

**maharam**

Mixed Stripe was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 15, smoke 35

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.