

Flame Certificate
Square Cutter's Room
by Rosemarie Trockel
399754

maharam

Square Cutter's Room was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact clientservices@maharam.com with any questions.