

Flame Certificate  
Fruit Tree  
by Alexander Girard®, 1961  
399770

**maharam**

Fruit Tree was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 25, smoke 45

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.