Flame Certificate
Sfumato
399780

maharam

Sfumato was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact clientservices@maharam.com with any questions.