

Flame Certificate

Lumen

399981

maharam

Lumen was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame 20, smoke 45

Contact clientservices@maharam.com with any questions.