

Flame Certificate

Perch

399996

maharam

Perch was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 20, smoke 45

Contact clientservices@maharam.com with any questions.