

Flame Certificate

Emit

466378

maharam

Emit was tested and met the following flammability requirements:

Seating: California Bulletin #117-2013

Systems: ASTM E 84 Unadhered

Upholstered Walls: ASTM E 84 Unadhered flame 10, smoke 50

Contact clientservices@maharam.com with any questions.