

Flame Certificate
Levity
466518

maharam

Levity was tested and met the following flammability requirements:
Seating: California Bulletin #117-2013
Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 75

Contact clientservices@maharam.com with any questions.